



LATI Industria Termoplastici S.p.A.
Via Francesco Baracca, 7
I-21040 VEDANO OLONA VA
ITALY

Rotthauer Str. 19
45879 Gelsenkirchen

Telephone +49 (209) 9242-0
Extension +49 (209) 9242-351
Telefax +49 (209) 9242-212
E-Mail a.bernoussi@hyg.de
Internet www.hyg.de

Reference: K-181780-09-Bs
Contact person: Mr. Bernoussi (Eng.)

Gelsenkirchen, 23.09.2009

TEST CERTIFICATE according to the KTW-Guideline

Product: LATIGLOSS 66H2 G/50 NAT.: 0003F2
LATIGLOSS 66H2 G/50 BLACK: 3352F2

Test specimen: plates

Kind of test: Product test / Permission test Supervision test

The a.m. **LATIGLOSS 66H2 G/50 (nat. and black)** meets the requirements according to the test report dated **23.09.2009**
Ref.-No.: K-181780-09-Bs for the following applications and temperatures:

Applications:	cold water (23°C)	moderately hot water (60°C)	extremely hot water (85°C)
Pipes ID < 80 mm (domestic distribution)	---	---	---
Pipes 80 mm ≤ ID < 300 mm (supply pipelines)	---	---	---
Pipes ID ≥ 300 mm (mains)	---	---	---
Simple fittings, assembled product housings for pipes ID < 80 mm	passed	---	---
Simple fittings, assembled product housings for pipes 80 mm ≤ ID < 300 mm	passed	---	---
Simple fittings, assembled product housings for pipes ID ≥ 300 mm	passed	---	---
Seals for pipes ID < 80 mm	passed	---	---
Seals for pipes 80 mm ≤ ID < 300 mm	passed	---	---
Seals for pipes ID ≥ 300 mm	passed	---	---
Storage systems within the domestic distribution system including repair products	---	---	---
Storage systems outside the domestic distribution system including repair products	---	---	---

as far as technically suited.

This test certificate is valid beginning with the date of issue and is ending by **23.09.2014** as far as there are no changes in the formula. After this time it can be extended for further 5 years if demanded.

The Director of the Institute
on behalf of

(Dr. rer. nat. A. Koch)
Head of the Dept. for water
hygienic material examinations



The results and conclusions exclusively refer to the investigated samples and the relevant laws.
The validity of this document expires in case of modifications in the composition of the product or the processing conditions.
This document must not be reproduced except in full, without our written approval.

